

O/O DIMENSION
(SEE PLAN)

NOTE:
REFERENCE TYPICAL TRIM
LAP SECTIONS

URETHANE SEALANT [HW-54_] @ CLOSURE ENDS/PANEL RIB & LAPPING CLOSURE TABS TO SEAL ALL VOIDS

1/4-14 x 7/8 LONG-LIFE LAPTEK W/WASHER [FASTENER #4] SPACED 1 1/2" FROM PANEL SEAMS, W/ INTERIOR FASTENERS CENTERED OVER MINOR RIBS (7" O.C. MAX.) (NO FASTENER @ PANEL SEAM)

TRI-BEAD TAPE SEALER [HW-504]

LOW SLIDING CLIP [HW-2122]

DOUBLE-LOK PANEL

WALL PANEL

INSIDE CLOSURE

PARAPET HIGH EAVE FLASHING [FL-2_] 2"

2 x 4 x 16 GA. ANGLE

12-14 x 1 1/4 LONG-LIFE SELF-DRILLER W/WASHER [FASTENER #3]

1/4-14 x 1 1/4 SELF-DRILLER W/O WASHER [FASTENER #1B] @ 12" O.C.

WALL GIRT

12

1/4-14 x 1 1/4 LONG-LIFE SELF-DRILLER W/WASHER [FASTENER #1E] (3) PER PANEL

METAL OUTSIDE CLOSURE

[HW-430] 24" PANEL

[HW-432] 18" PANEL

[HW-442] 12" PANEL

BACK-UP PLATE

[HW-7760] 24" PANEL

[HW-7769] 18" PANEL

[HW-7761] 12" PANEL

TRI-BEAD TAPE SEALER [HW-504]

1/4-14 x 5/8 LONG-LIFE 'TYPE B' SELF-TAPPER W/WASHER [FASTENER #46] @ PRE-PUNCHED HOLES

(6) PER 24" PANEL

(5) PER 18" PANEL

(4) PER 12" PANEL

3/8"

RIGID INSULATION (NOT BY MBCI)
VAPOR BARRIER (NOT BY MBCI)
METAL DECK (MIN. GAUGE THICKNESS) (NOT BY MBCI)

BEARING PLATE [HW-7500]

14-10 x ____ DECK SCREW [FASTENER #15_] (2) PER CLIP (MIN. 3/4" PENETRATION INTO METAL DECK)

6"

2"

WALL PANEL WIDTH

